



Certificate of Compliance

Certificate Number: LR 26243-16

Revision: LR 26243-18

Date Issued: April 24, 1998

Issued to: **O'BRIEN CORPORATION**
1900 Crystal Industrial Ct.
St. Louis, MO 63114
USA
Attention: Mr. Mike Pellegrini

The products listed below are eligible to bear the CSA Mark

Issued by: D. Somma, C.E.T.
Toronto, ON Canada

Signature: _____

CLASS

2878 02 - HEATERS - Miscellaneous - For Hazardous Locations

PRODUCTS

Class I, Div. 1 and 2, Groups A, B, C and D; Class II, Div. 1 and 2; Class III, Div. 1 and 2; Type 4;
Class I, Zone 1 and 2, Group IIB + H₂;

Model TPC1 Hazardous Location Power Connection Kit consisting of an integral seal gland for use with electric surface strip heaters Types BTV-C, -CR, -CT and XTV-C, -CT manufactured by "Raychem".

Notes:

1. The integral seal gland is to be used with an approved junction box having a maximum volume of 2000cm³.
2. Installation instruction sheets provided within each package.



Revision: LR 26243-18

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	25-1966-Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CSA Std C22.2 No.	30-M1986-Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No.	94-M91-Special Purpose Enclosures
CSA Std C22.2 No.	138-M1989-Heat Tracing Cable and Cable Sets for Use in Hazardous Locations

MARKINGS

Embossed lettering on each gland cap.

- Manufacturer's name or trademark;
- Model Number Designation;
- Hazardous Location Designation (eg: Class I, Div. 1 and 2, Groups B, C and D; Class II, Div. 1 and 2, Class III, Type 4)*.
- The letters "SL";
- Reference to Installation Instructions;
- Type 4 Designation (Watertight);
- CSA Monogram.

Notes:

1. Installation instruction provided in each package.
2. * May be optionally marked with the addition of Class I, Zone 1 and 2, Groups IIB + H₂.



Supplement to Certificate of Compliance

Certificate Number: LR 26243-16

Issued to: **O'BRIEN CORPORATION**
1900 Crystal Industrial Ct.
St. Louis, MO 63114
USA
Attention: Mr. Mike Pellegrini

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: D. Somma, C.E.T.
Toronto, ON Canada

Signature: _____

Product Certification History

Revision	Date	Description
-18	April 24/98	To cover the addition of zone marking equivalent.
-16	Oct. 8/91	Original Certification.